



Efficiency Of Control Gear TEST REPORT

Of IEC 62384:2006+A1:2009 Applied for SASO-2927

Kunde: <i>Client:</i>	AOK Industrial Company Limited
Adresse: <i>Address:</i>	Building 1, Shengzuozhi Technology Industrial Park, Shajing Street, Shenzhen City, Guangdong, P.R. China
Hersteller: <i>Manufacturer:</i>	INVENTRONICS (HANGZHOU) , INC
Adresse: <i>Address:</i>	Inventronics Science and Technology Park , , # 459 Jianghong Rd , Binjiang, 310053 HANGZHOU, ZHEJIANG, PEOPLES REPUBLIC OF CHINA
Name der Marke: <i>Brand Name:</i>	INVENTRONICS®
Beschreibung des Produkts: <i>Product Description:</i>	LED Driver
Modelle: <i>Models:</i>	EUM-150S420MG
Bewertung: <i>Rating:</i>	100-277V~, 50/60Hz, 150W
Verfahren: <i>Method:</i>	SASO 2927: 2019:Energy efficiency functionality and labelling requirements for lighting products – Part 3: Street lighting IEC 62384:2006+A1:2009: LED DC or AC supplied electronic control gear for LED modules performance requirements. IEC 60529:1989+A1:1999+A2:2013: Degrees of protection provided by enclosures (IP Code)
Prüfergebnis*: <i>Test result*:</i>	IP66 No deposit of talcum powder inside enclosures for dust-tight control gear; No water entry control gear;Function Normal

Datum der Prüfung: <i>Date of Test:</i>	Datum der Emission: <i>Date of Issue:</i>	Klassifizierung: <i>Classification:</i>	Gegenstand der Prüfung: <i>Test item:</i>
2021-06-16--2021-06-21	2021-09-03	Commission Test	Efficiency of Control Gear; IP

Prüflabor (Testlabor) / Testing Laboratory:
Shenzhen Southern LCS Compliance Testing Laboratory Ltd.

Test von/Prepare by: <i>Seth Cai</i> Seth Cai/ Project Engineer	Check von/Check by: <i>Ian Luo</i> Ian Luo/ Director	Genehmigt von/Approved by: <i>Jesse Liu</i> Jesse Liu/ Manager
--	---	---



Dieser Prüfbericht bezieht sich nur auf das o.g. Prüfmuster und darf ohne Genehmigung der Prüfstelle nicht auszugsweise vervielfältigt werden. Dieser Bericht berechtigt nicht zur Verwendung eines Prüfzeichens.

Remark: The duplication of this report or parts of it and its use for advertising purposes is only allowed with permission of the testing laboratory. This report contains the result of examination of the product sample submitted by the appliance. A general statement concerning the quality of the products from the series manufacturer cannot be derived therefore.

**General remarks:**

“(See attachment#)” refers to additional information appended to the report.

“(See remark#)” refers to a remark appended to the report.

“(See appended table)” refers to a table appended to the report.

Throughout this report a comma (point) is used as the decimal separator.

Remark:

Measurement was conducted at a stable ambient temperature $25^{\circ}\text{C} \pm 1^{\circ}\text{C}$.

Possible test case verdicts:

- test case does not apply to the test object : N/A (Not applicable)
- test object does meet the requirement : P (Pass)
- test object does not meet the requirement : F (Fail)

Equipment list for test:

Item	Equipment No	Equipment	Manufacturer / Type / Series No
1	SLCS-S-004	Digital Power Meter	YOKOGAWA/ WT210 / 91L424211
2	SLCS-S-066	Digital Multimeter	FLUKE/Fluke15B

**Test Item:**

Tests for protection against dust-proof: IP6X

Test Method:

The tests should be carried out under the standard atmospheric condition.

Temperature range: 20°C to 30°C

Dust-proof luminaires (first characteristic IP numeral 5) shall be tested in a dust chamber similar to that shown in Figure 6, in which talcum powder is maintained in suspension by an air current. The chamber shall contain 2 kg of powder for every cubic metre of its volume. The talcum powder used shall be able to pass through a square-meshed sieve whose nominal wire diameter is 50 μ m and whose nominal free distance between wires is 75 μ m. It shall not have been used for more than 20 tests.

The test shall proceed as follows.

- a) The luminaire is suspended outside the dust chamber and operated at rated supply voltage until operating temperature is achieved.
- b) The luminaire, whilst still operating, is placed with the minimum disturbance in the dust chamber.
- c) The door of the dust chamber is closed.
- d) The fan/blower causing the talcum powder to be in suspension is switched on.
- e) After 1 min, the luminaire is switched off and allowed to cool for 3 h whilst the talcum powder remains in suspension.

NOTE: The 1 min interval between switching on the fan/blower and switching off the luminaire is to ensure that the talcum powder is properly in suspension around the luminaire during initial cooling, which is most important with smaller luminaires. The luminaire is operated initially as in item a) to ensure the test chamber is not overheated.


Acceptance Conditions:

After completion of the tests, the luminaire shall withstand the electric strength test specified in Section 10, and inspection shall show:

No deposit of talcum powder inside enclosures for dust-tight luminaires

Test Result:

☒ Pass ☐ Fail



IEC 280/01

NOTE See IEC 60068-2-68, figure 2 valid for La2 only.

Figure 2 – Test device to verify protection against dust (dust chamber)

**Test Item:**

Tests for protection against ingress moisture: IPX6

Test Method:

The tests should be carried out under the standard atmospheric condition.

Temperature range: 20°C to 30°C

Powerful water jet-proof luminaires (second characteristic IP numeral 6) are switched off and immediately subjected to a water jet for 3 min from all directions by means of a hose having a nozzle with the shape and dimensions shown in Figure 8. The nozzle shall be held 3 m away from the sample.

The water pressure at the nozzle shall be adjusted to achieve a water flow rate of 100 l/min \pm 5 % (approximately 100 kN/m²).

Before the tests for the second characteristic numeral, with the exception of IPX8, the luminaire complete with lamp(s) shall be switched on and brought to a stable operating temperature at rated voltage.

The water for the tests shall be at a temperature of 15 °C \pm 10 °C

Luminaires shall be mounted and wired as in normal use and placed in the most unfavourable position, complete with their protective translucent covers, if any, for the tests of IP.

Where connection is made by a plug or a similar device, then this shall be regarded as part of the complete luminaire and shall be included in the tests and similarly for any separate controlgear.

For tests of IP, fixed luminaire intended for mounting with its body in contact with a surface shall be tested with an expanded metal spacer interposed between the luminaire and the mounting surface. The spacer shall be at least equal in overall size to the projection of the luminaire, and have dimensions as follows:

Longway of mesh	10 mm to 20 mm
Shortway of mesh	4 mm to 7 mm
Strand width	1,5 mm to 2 mm
Strand thickness	0,3 mm to 0,5 mm
Overall thickness	1,8 mm to 3 mm

Luminaires having provision for draining water by means of drain holes shall be mounted with the lowest drain hole open unless otherwise specified in the manufacturer's installation instructions

If the installation instructions indicate that a luminaire is for ceiling or under-canopy mounting, the luminaire shall be attached to the underside of a flat board or plate which extends 10 mm beyond that part of the luminaire perimeter in contact with the mounting surface

For recessed luminaires, the parts in the recess and the parts protruding from the recess shall each be tested according to their IP classification as indicated in the manufacturer's mounting instructions. A box encapsulating the part in the recess may be necessary for the test of IP.



Note: Portable luminaires, wired as in normal use, shall be placed in the most unfavourable position of normal use.

Glands, if any, shall be tightened with a torque equal to two-thirds of that applied to glands in the test of 4.12.5.

Fixing screws of covers, other than hand-operated fixing screws of glass covers, shall be tighter with a torque equal to two-thirds of that specified in Table 4.1.

Screwed lids shall be tightened with a torque having a value in newton metres numerically equal to one-tenth of the nominal diameter of the screw thread in millimetres. Screws fixing other caps shall be tightened with a torque equal to two-thirds of that specified in Table 4.1.

Acceptance Conditions:

After completion of the tests, the luminaire shall withstand the electric strength test specified in Section 10, and inspection shall show:


no trace of water on electrical connections, current carrying parts or on insulation where it could become a hazard for the user or surroundings, for example where it could reduce the creepage distances below the values specified in Section 11; the only exception to this is for SELV conductors where the voltage under load does not exceed 12 V r.m.s. or 30 V ripple free d.c. and the conductors are protected from corrosion.

For luminaires without drain holes, there shall be no water entry.


For luminaires with drain holes, water entry including condensation is allowed during the tests if it can drain out effectively and provided it does not reduce the creepage and clearance distances below the minimum levels specified in the standard

Test Result:

☒ **Pass** ☐ **Fail**



$D' = 6,3 \text{ mm}$ for the test of 9.2.6 (second characteristic numeral 5)
 $D' = 12,5 \text{ mm}$ for the test of 9.2.7 (second characteristic numeral 6)



IEC 492/08

Dimensions in millimetres

Figure 8 – Nozzle for spray test


Table 4.1 – Torque tests on screws

Nominal outer thread diameter of screw mm	Torque Nm		
	1	2	3
Up to and including 2,8	0,20	0,40	0,40
Over 2,8 up to and including 3,0	0,25	0,50	0,50
Over 3,0 up to and including 3,2	0,30	0,60	0,50
Over 3,2 up to and including 3,6	0,40	0,80	0,60
Over 3,6 up to and including 4,1	0,70	1,20	0,60
Over 4,1 up to and including 4,7	0,80	1,80	0,90
Over 4,7 up to and including 5,3	0,80	2,00	1,00
Over 5,3 up to and including 6,0	–	2,50	1,25
Over 6,0 up to and including 8,0	–	8,00	4,00
Over 8,0 up to and including 10,0	–	17,00	8,50
Over 10,0 up to and including 12,0	–	29,00	14,50
Over 12,0 up to and including 14,0	–	48,00	24,00
Over 14,0 up to and including 16,0	–	114,00	57,00

Table 4.2 – Torque tests on glands

Diameter of test rod mm	Moment	
	Metal glands Nm	Moulded plastic glands Nm
Up to 7	6,25	2,5
Over 7 up to 14	6,25	3,25
Over 14 up to 20	7,50	5
Over 20	10	7,50

Withstand the electric strength after IP6X test:		
Test Location	Test Voltage	Broken or Flashover
Live parts and accessible parts	500V	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Withstand the electric strength after IPX6 test:		
Live parts and accessible parts	500V	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No



Control Gear model	EUM-150S420MG			
Sample No.	No Load Power of Control Gear (W)	Stand by Power of Control Gear (W)	Power of Control Gear (W)	Efficiency of Control Gear (%)
1	0.34	0.34	159.15	94.25%
2	0.28	0.28	159.73	93.91%
3	0.28	0.28	159.54	94.02%
4	0.33	0.33	160.21	93.63%
5	0.30	0.30	160.07	93.71%
6	0.24	0.24	160.81	93.28%
7	0.41	0.41	159.95	93.78%
8	0.22	0.22	160.15	93.66%
9	0.26	0.26	159.76	93.89%
10	0.37	0.37	160.70	93.34%
Avg.	0.30	0.30	160.01	93.75%

Electrical Requirements result

Requirement - Test	Result - Remark	Verdict
The control unit shall be equipped with internal protection to withstand charges and lightning of not less than 4 kV	10KV	P
Constant Voltage Drivers are not allowed to be used; drivers shall be programmable whether DALI (preferable) or 0-10V dimmable	0-10V dimmable	P
The control units (Driver) must operates with voltage (120-277) Vac at 60 Hz	100-277 Vac at 60 Hz	P
The Power factor value for driver and integrated luminaire shall be ≥ 0.9	≥ 0.92	P
Total Harmonic Distortion of the driver individually < 15%	2.35%	P
The control gear in the lighting fixtures shall have IP66 protection levels	IP66	P
The control unit enclosure shall be designed to withstand a temperature between -10 and +85.	-10 and +80	P



Photo of sample

Photo document

Photos 1 of Control Gear



Photos 2: IP6X test of model EUM-150S420MG



Photo 3: IP6X test of model EUM-150S420MG



Photo 4: Test result after IP6X and IPX6 test (no dust & no water)



**Revision History**

Revision	Issue Date	Revision Content	Revised By
V1.1	2021/09/03	Modify the Client	Seth Cai

Remark: This report is based on the report No. LCS200722070BS. This report is invalid without the original report.

----- End of test report -----